



**November 11, 2013**

# **Midcontinent ISO Affected System Impact Study**

**Prepared for:** Midcontinent ISO

**Prepared by:** Quanta Technology, LLC

**Contacts:** **Ed Pfeiffer**  
[epfeiffer@quanta-technology.com](mailto:epfeiffer@quanta-technology.com)  
919 334 3054

**Xiaohuan Tan**  
[xtan@quanta-technology.com](mailto:xtan@quanta-technology.com)  
919 334 3073



## Table of Contents

<b>1</b>	<b>EXECUTIVE SUMMARY .....</b>	<b>4</b>
<b>2</b>	<b>STUDY METHODOLOGY &amp; ASSUMPTIONS.....</b>	<b>5</b>
2.1	STUDY CRITERIA .....	5
2.2	BASE CASE DEVELOPMENT .....	5
2.3	STUDY METHODOLOGY .....	7
2.4	STUDY ASSUMPTIONS .....	8
<b>3</b>	<b>POWER FLOW ANALYSIS RESULTS.....</b>	<b>9</b>
3.1	THERMAL RESULTS BY DC ANALYSIS .....	9
3.1.1	2016 Results.....	9
3.1.2	2023 Results.....	9
3.2	THERMAL RESULTS BY AC ANALYSIS .....	9
<b>4</b>	<b>CONCLUSIONS .....</b>	<b>9</b>
<b>APPENDIX A</b>	<b>STEADY STATE ANALYSIS INPUT FILES .....</b>	<b>10</b>
A.1	SUBSYSTEM FILE .....	10
A.2	MONITORED ELEMENT FILE.....	20
A.3	CONTINGENCY FILES .....	21



List of Tables

TABLE 2-1 PLANNING CRITERIA REQUIREMENTS ..... 5

TABLE 2-2 PJM GENERATION INTERCONNECTION PROJECTS STUDIED ..... 6

TABLE 2-3 STUDY REGION ..... 7



## 1 Executive Summary

This report documents the system thermal impacts of thirty-four (34) projects in the PJM generator interconnection queue on the Midcontinent Independent System Operator (“MISO”) transmission system, with a proposed combined maximum output of 7,477.2 MW.

The linear transfer analysis (DC analysis) did not identify any steady state thermal violations with the interconnection of the thirty-four PJM projects on the monitored MISO transmission system based on a standard FCITC calculation using a 3% TDF cutoff.



## 2 Study Methodology & Assumptions

### 2.1 Study Criteria

All interconnection requirements are based on the applicable MISO Transmission Planning Criteria and NERC Reliability Standards. The criteria used in this study are shown in Table 2-1.

**Table 2-1 Planning Criteria Requirements**

System Event	Steady State Thermal
Category A Intact System	All transmission facilities <100% of Normal Seasonal Rating (Rate A)
Category B Single Contingency	All transmission facilities <100% of Emergency Seasonal Rating (Rate B)
Category B Single Contingency	At 100% of the combined capacity of the all queue entries, no overloads for which MW impact of the queue injection exceeds 20% of the Emergency Seasonal Rating (Rate B)
Category C / D Selected Multiple Contingencies & Extreme Events	Violations of Category B Criteria will be noted.

### 2.2 Base Case Development

All steady state analysis performed in this study was based on the following 2016 and 2023 summer peak (“SPK”) and shoulder peak (“SH”) base cases provided by MISO:

- BaseCase-DPP-Feb13\_2016SH\_050813\_v33.sav
- BaseCase-DPP-Feb13\_2016spk\_050813\_v33.sav
- BaseCase-DPP-Feb13\_2023SH\_050813\_v33.sav
- BaseCase-DPP-Feb13\_2023SPK\_050813\_v33.sav

The detail of each PJM interconnection request is listed in Table 2-2. Wind-based generation was dispatched at 20% of requested maximum MW output in the SPK condition and 100% of nameplate in the SH condition. Generations of other fuel types were modeled at 100% of their nameplate capacity. All PJM interconnection requests were dispatched to the PJM system.

**Table 2-2 PJM Generation Interconnection Projects Studied**

<b>PJM Queue Entry</b>	<b>PJM Substation</b>	<b>State</b>	<b>Max-Output (MW)</b>	<b>Fuel Type</b>
S73	Lincoln – North Delphos 138kV	IN	200.0	wind
T130	Convoy – East Lima 345kV	OH	300.0	wind
T131	Lincoln – Sterling 138kV	OH	150.0	wind
T142	Southwest Lima – Marysville 345kV	OH	300.0	wind
T143	Hennepin 138kV	IL	250.0	wind
T148	Caledonia Wind II 100 MW	IL	100.0	wind
T94	Cook – Palesades 345kV	MI	1035.0	natural gas
T99	Caledonia Wind 100 MW	IL	100.0	wind
U1-049	Kankakee #4 138kV	IL	100.0	wind
U2-028A_AT1	Ironville 138kV	OH	135.0	other
U2-072	East Lima – Marysville 345kV	OH	300.0	wind
U3-021	Silver Lake – Cherry Valley 345kV	IL	100.0	natural gas
U4-027	Normandy-Kewanee 138kV	IL	100.0	natural gas
V1-011	Haviland 138kV	OH	100.0	wind
V1-012	Haviland 138kV	OH	150.0	wind
V2-006	East Leipsic 138kV	OH	150.0	wind
V2-042A_AT2	Galion 138kV	OH	200.0	wind
V3-007	Desoto-Tanners Creek #1 345kV	IN	200.0	wind
V3-008	Desoto-Tanners Creek #1 345kV	IN	200.0	wind
V3-009	Desoto-Tanners Creek #1 345kV	IN	200.0	wind
V3-053	Desoto 138kV	IN	150.0	wind
V4-010	Tiffin Center 138kV	OH	200.0	wind
V4-015	Fostoria Central 138kV	OH	66.6	wind
V4-016	Valley 138kV	MI	200.0	wind
W1-070A_AT4	Ashtabula 138kV	OH	50.0	wind
W1-072A_AT5	Lemoyne 345kV	OH	40.0	natural gas
W2-001	Fostoria Central 138kV	OH	66.6	wind
W3-059A_At6	Avery – Greenfield 138kV	OH	99.0	wind
W3-088	South West Lima 345kV	OH	200.0	wind
W3-128	Sporn – Waterford 345kV	OH	652.0	natural gas
W3-170	Buckskin 69kV	OH	12.0	solar
X1-027A_AT12	Davis Besse – Beaver 345kV	OH	500.0	wind
Y1-006	Jubal Early – Austinville 138kV	VA	72.0	wind
Y1-069	Bay Shore – Fostoria Central 345kV	OH	799.0	natural gas
<b>Total</b>			<b>7,477.2</b>	



## 2.3 Study Methodology

The steady state analysis was performed to identify the thermal violations on the MISO system caused by the PJM interconnection projects. Linear transfer analysis was performed using the Linear Transfer Analysis modules of the version 11.0.1 of the Managing and Utilizing System Transmission (MUST, Version 11.0.1) program from Siemens Power Technologies, Inc (PTI). AC power flow solutions to verify constraints identified in the linear analysis were performed using the Power Flow module of the Power System Simulation/Engineering-33 (PSS/E, Version 33) program from PTI. These programs are accepted industry-wide for power flow analysis.

The study region defined in the monitoring file that MISO provided includes:

**Table 2-3 Study Region**

Area #	Area ID	Area Name	Subsystem
208	DEI	Duke Energy Indiana	STUDY_CENTRAL
210	SIGE	Southern Indiana Gas & Electric Company	
216	IPL	Indianapolis Power & Light Company	
217	NIPS	Northern Indiana Public Service Company	
333	CWLD	Columbia, MO Water and Light	
356	AMMO	Ameren Missouri	
357	AMIL	Ameren Illinois	
360	CWLP	City of Springfield (IL) Water Light & Power	
361	SIPC	Southern Illinois Power Cooperative	
222	CE	Commonwealth Edison	
330	AECI	Associated Electric Cooperative Inc.	STUDY_SEAMS
540	GMO	Greater Missouri Operations Company	
541	KCPL	Kansas City Power and Light Company	
542	KACY	Board of Public Utilities	
545	INDN	City of Independence	
640	NPPD	Nebraska Public Power District	
645	OPPD	Omaha Public Power District	
650	LES	Lincoln Electric System, NE	
652	WAPA	Western Area Power Administration	
295	WEC	Wisconsin Electric Power Company (ATC)	STUDY_WEST
600	XEL	Xcel Energy North	
608	MP	Minnesota Power & Light	
613	SMMPA	Southern Minnesota Municipal Power Association	
615	GRE	Great River Energy	
620	OTP	Otter Tail Power Company	
627	ALTW	Alliant Energy West	
633	MPW	Muscatine Power & Water	



Area #	Area ID	Area Name	Subsystem
635	MEC	MidAmerican Energy	
661	MDU	Montana-Dakota Utilities Co.	
667	MHEB	Manitoba Hydro	
680	DPC	Dairyland Power Cooperative	
694	ALTE	Alliant Energy East (ATC)	
696	WPC	Wisconsin Public Service Corporation (ATC)	
697	MGE	Madison Gas and Electric Company (ATC)	
698	UPPC	Upper Peninsula Power Company (ATC)	

All facilities in the study region with a voltage of 69kV and above were monitored. The MISO provided contingencies include single branch, single unit, and selected multi-element contingencies on facilities in the study region and part of the surrounding control areas.

Thermal overloads were identified using linear transfer with DC power flow solutions to evaluate the intact system, N-1 contingency and certain multiple contingency conditions. Transmission reserve margin (“TRM”) is not used (i.e., 0% TRM) in the analysis.

The MISO Business Practices Manual states that for NERC Category B contingencies, all study region facilities with powers flows above the rated limits and TDFs (Transfer Distribution Factors) of greater than 5% were flagged as violations for both system intact conditions and under contingencies. The MISO criteria used to determine constraints refer to all thermal overloads with  $DF \geq 5\%$  under system intact conditions, or  $DF \geq 20\%$  under Category B contingency, an overload of a generator outlet or an overload caused by the outage of a generator outlet, or the MW impact due to the study generation is  $\geq 20\%$  of the overloaded facility ratings.

For NERC category C contingencies, all study region facilities with powers flows 25% above the rated limits, or TDFs  $\geq 3\%$ , or the MW impact  $\geq 20\%$  of the overloaded facility applicable rating were flagged as potential constraints for further review.

The system impact analysis performed in this group study was a traditional FCITC calculation using a source consisting of all of the queued projects and a sink modeled as the whole of PJM. The full nameplate capacity of the PJM queue projects was modeled as the source in the SH cases and the rated deliverable capacity was modeled as the source in the SPK cases. The MUST runs used a 3% TDF cutoff.

## 2.4 Study Assumptions

This affected system impact study was conducted with all the PJM participating generators operating together as a group. Analysis was not performed on individual generating units or subsets of the generating units unless specifically noted otherwise. The results obtained in this analysis will change if any of the data or assumptions which were made during the development of the study models is revised.





### **3 Power Flow Analysis Results**

#### **3.1 Thermal Results by DC Analysis**

##### **3.1.1 2016 Results**

No thermal violations attributed to the PJM interconnection requests were identified in MISO system under the 2016 SPK nor SH condition by the DC transfer analysis using the DF cutoff criterion.

##### **3.1.2 2023 Results**

No thermal violations attributed to the PJM interconnection requests were identified in MISO system under the 2023 SPK nor SH condition by the DC transfer analysis using the DF cutoff criterion.

#### **3.2 Thermal Results by AC Analysis**

As there was no FCITC binding contingency and thermal violation pairs identified in the study region by the DC analysis, no AC analysis was performed to verify the contingency/monitor pairs.

### **4 Conclusions**

The linear transfer analysis (DC analysis) did not identify any steady state thermal violations with the interconnection of the thirty-four PJM projects on the monitored MISO transmission system using a 3% TDF cutoff criterion.



## Appendix A Steady State Analysis Input Files

### A.1 Subsystem File

Following subsystem definitions were used in the MUST linear transfer analysis.

/ For DPP August Cycle study  
/ updated U3-021 and U2-072 on 7/8/2013

```
SUBSYSTEM 'STUDY_CENTRAL'  
  AREA 333 / cwld  
  AREA 356 / AMMO  
  AREA 357 / AMIL  
  AREA 217 / NIPS  
  AREA 208 / DEM  
  AREA 210 / SIGE  
  AREA 216 / IPL  
  AREA 360 / CWLP  
  AREA 361 / SIPC  
END
```

```
SUBSYSTEM 'STUDY_WEST'  
  AREA 295 / WEC  
  AREA 600 / XEL  
  AREA 608 / MP  
  AREA 613 / SMMPA  
  AREA 615 / GRE  
  AREA 620 / OTP  
  AREA 627 / ALTW  
  AREA 633 / MPW  
  AREA 635 / MEC  
  AREA 661 / mdu  
  AREA 680 / DPC  
  AREA 694 / ALTE  
  AREA 696 / WPS  
  AREA 697 / MGE  
  AREA 698 / UPPC  
END
```

```
Subsystem 'STUDY_SEAMS'  
/ AREA 222 / CE  
  AREA 330 / AECI  
  AREA 640 / NPPD  
  AREA 645 / OPPD  
  AREA 650 / LES  
  AREA 652 / WAPA  
  AREA 540 / MIPU  
  AREA 541 / KCPL  
  AREA 542 / KACY  
  AREA 545 / INDN
```



end

Subsystem 'CENTRAL\_SEAMS'

    AREA 333     / CWLD  
    AREA 356 / AMMO  
    AREA 357 / AMIL  
    AREA 222 / CE  
    AREA 330 / AECI  
    AREA 640 / NPPD  
    AREA 645 / OPPD  
    AREA 650 / LES  
    AREA 652 / WAPA

end

SUBSYSTEM PJM\_im

    AREAS 201 209  
    AREAS 222 235  
    scale ALL for import

END

subsystem   s-073

    participate include offline  
    bus   884501       160  
    bus   884502       40  
    end

end

subsystem   t-094

    participate include offline  
    bus   885601       1035  
    end

end

subsystem   t-099

    participate include offline  
    bus   885611       20  
    bus   885612       80  
    end

end

subsystem   t-130

    participate include offline  
    bus   885621       60  
    bus   885622       240  
    end

end

subsystem   t-131

    participate include offline  
    bus   885631       30  
    bus   885632       120  
    end

end

subsystem   t-142

    participate include offline  
    bus   885641       60



```
        bus      885642      240
        end
    end
    subsystem    t-143
        participate include offline
        bus      885651      50
        bus      885652      200
        end
    end
    subsystem    t-148
        participate include offline
        bus      885661      20
        bus      885662      80
        end
    end
    subsystem    u1-049
        participate include offline
        bus      887601      13
        bus      887602      87
        end
    end
    subsystem    u2-028a
        participate include offline
        bus      889001      135
        end
    end

/* Withdrew 07/08/2013
    subsystem    u2-062
        participate include offline
        bus      889031      12.2
        bus      889032      81.8
        bus      889041      12.2
        bus      889042      81.8
        end
    end

    subsystem    u2-072
        participate include offline
        bus      889031      39
        bus      889032      261
        end
    end
    subsystem    u3-021
        participate include offline
        bus      890511      50
        bus      890501      50
        end
    end
    subsystem    u4-027
        participate include offline
        bus      891001      100
```



```
end
end
subsystem v1-011
  participate include offline
  bus 892001 13
  bus 892002 87
end
end
subsystem v1-012
  participate include offline
  bus 892011 19.5
  bus 892012 130.5
end
end
subsystem v2-006
  participate include offline
  bus 893011 19.5
  bus 893012 130.5
end
end
subsystem v2-042a
  participate include offline
  bus 893000 26
  bus 893001 174
end
end
subsystem v3-007
  participate include offline
  bus 894501 26
  bus 894502 174
end
end
subsystem v3-008
  participate include offline
  bus 894511 26
  bus 894512 174
end
end
subsystem v3-009
  participate include offline
  bus 894521 26
  bus 894522 174
end
end
subsystem v3-053
  participate include offline
  bus 894540 19.5
  bus 894541 130.5
end
end
subsystem v4-010
  participate include offline
```



```
        bus    900001      26
        bus    900002     174
        end
    end
    subsystem   v4-015
        participate include offline
        bus    900011      8.6
        bus    900012      58
        end
    end
    subsystem   v4-016
        participate include offline
        bus    900021      26
        bus    900022     174
        end
    end
    subsystem   w1-070a-at4
        participate include offline
        bus    901001      6.5
        bus    901002     43.5
        end
    end
    subsystem   w1-072a_at5
        participate include offline
        bus    901011      40
        end
    end
    subsystem   w2-001
        participate include offline
        bus    902141      8.6
        bus    902142      58
        end
    end
    subsystem   w3-059a_at6
        participate include offline
        bus    903201     12.9
        bus    903202     86.1
        end
    end
    subsystem   w3-088
        participate include offline
        bus    903211      26
        bus    903212     174
        end
    end
    subsystem   w3-128
        participate include offline
        bus    903221     652
        end
    end
    subsystem   w3-170
        participate include offline
```



```

        bus    903232      12
        end
    end
    subsystem  x1-027a
        participate include offline
        bus    907001      65
        bus    907002      435
        end
    end
    subsystem  y1-006
        participate include offline
        bus    913001      9.36
        bus    913002      62.64
        end
    end
    subsystem  y1-069
        participate include offline
        bus    913011      799
        end
    end
    subsystem  ICQ_Total_SH
        participate include offline
        subsystem  s-073      200
        subsystem  t-094      1035
        subsystem  t-099      100
        subsystem  t-130      300
        subsystem  t-131      150
        subsystem  t-142      300
        subsystem  t-143      250
        subsystem  t-148      100
        subsystem  u1-049      100
        subsystem  u2-028a     135
        subsystem  u2-072      300
        subsystem  u3-021      100
        subsystem  u4-027      100
        subsystem  v1-011      100
        subsystem  v1-012      150
        subsystem  v2-006      150
        subsystem  v2-042a     200
        subsystem  v3-007      200
        subsystem  v3-008      200
        subsystem  v3-009      200
        subsystem  v3-053      150
        subsystem  v4-010      200
        subsystem  v4-015      66.6
        subsystem  v4-016      200
        subsystem  w1-070a-at4  50
        subsystem  w1-072a_at5  40
        subsystem  w2-001      66.6
        subsystem  w3-059a_at6  99
        subsystem  w3-088      200
        subsystem  w3-128      652
    end

```



```
        subsystem    w3-170        12
        subsystem    x1-027a       500
        subsystem    y1-006        72
        subsystem    y1-069       799
    end
end
/
/subsystems for on peak studies
/
subsystem    s-073_op
    participate include offline
    bus      884502        40
    end
end
subsystem    t-094_op
    participate include offline
    bus      885601       1035
    end
end
subsystem    t-099_op
    participate include offline
    bus      885611        20
    end
end
subsystem    t-130_op
    participate include offline
    bus      885621        60
    end
end
subsystem    t-131_op
    participate include offline
    bus      885631        30
    end
end
subsystem    t-142_op
    participate include offline
    bus      885641        60
    end
end
subsystem    t-143_op
    participate include offline
    bus      885651        50
    end
end
subsystem    t-148_op
    participate include offline
    bus      885661        20
    end
end
subsystem    u1-049_op
    participate include offline
    bus      887601        13
```





```
end
end
subsystem    u2-028a_op
    participate include offline
    bus      889001      135
end
end
subsystem    u2-072_op
    participate include offline
    bus      889031      39
end
end
subsystem    u3-021_op
    participate include offline
    bus      890511      50
    bus      890501      50
end
end
subsystem    u4-027_op
    participate include offline
    bus      891001      100
end
end
subsystem    v1-011_op
    participate include offline
    bus      892001      13
end
end
subsystem    v1-012_op
    participate include offline
    bus      892011      19.5
end
end
subsystem    v2-006_op
    participate include offline
    bus      893011      19.5
end
end
subsystem    v2-042a_op
    participate include offline
    bus      893000      26
end
end
subsystem    v3-007_op
    participate include offline
    bus      894501      26
end
end
subsystem    v3-008_op
    participate include offline
    bus      894511      26
end
```



```
end
subsystem    v3-009_op
    participate include offline
    bus      894521      26
end
end
subsystem    v3-053_op
    participate include offline
    bus      894540      19.5
end
end
subsystem    v4-010_op
    participate include offline
    bus      900001      26
end
end
subsystem    v4-015_op
    participate include offline
    bus      900011      8.6
end
end
subsystem    v4-016_op
    participate include offline
    bus      900021      26
end
end
subsystem    w1-070a-at4_op
    participate include offline
    bus      901001      6.5
end
end
subsystem    w1-072a-at5_op
    participate include offline
    bus      901011      40
end
end
subsystem    w2-001_op
    participate include offline
    bus      902141      8.6
end
end
subsystem    w3-059a-at6_op
    participate include offline
    bus      903201      12.9
end
end
subsystem    w3-088_op
    participate include offline
    bus      903211      26
end
end
subsystem    w3-128_op
```



```

        participate include offline
        bus    903221      652
        end
    end
    subsystem    w3-170_op
        participate include offline
        bus    903232      12
        end
    end
    subsystem    x1-027a_op
        participate include offline
        bus    907001      65
        end
    end
    subsystem    y1-006_op
        participate include offline
        bus    913001      9.36
        end
    end
    subsystem    y1-069_op
        participate include offline
        bus    913011      799
        end
    end
    subsystem ICQ_Total_SPK
        participate include offline
        subsystem    s-073_op      40
        subsystem    t-094_op      1035
        subsystem    t-099_op      20
        subsystem    t-130_op      60
        subsystem    t-131_op      30
        subsystem    t-142_op      60
        subsystem    t-143_op      50
        subsystem    t-148_op      20
        subsystem    u1-049_op      13
        subsystem    u2-028a_op     135
        subsystem    u2-072_op      39
        subsystem    u3-021_op     100
        subsystem    u4-027_op     100
        subsystem    v1-011_op      13
        subsystem    v1-012_op     19.5
        subsystem    v2-006_op     19.5
        subsystem    v2-042a_op     26
        subsystem    v3-007_op     26
        subsystem    v3-008_op     26
        subsystem    v3-009_op     26
        subsystem    v3-053_op     19.5
        subsystem    v4-010_op     26
        subsystem    v4-015_op     8.6
        subsystem    v4-016_op     26
        subsystem    w1-070a-at4_op  6.5
        subsystem    w1-072a-at5_op  40
    end

```



```

subsystem w2-001_op 8.6
subsystem w3-059a_at6_op 12.9
subsystem w3-088_op 26
subsystem w3-128_op 652
subsystem w3-170_op 12
subsystem x1-027a_op 65
subsystem y1-006_op 9.36
subsystem y1-069_op 799
end
end
END

```

## A.2 Monitored Element File

Following monitored element definitions were used in the MUST linear transfer analysis.

```

monitor branches in subsystem 'STUDY_CENTRAL' in kvrage 60 800
monitor ties from subsystem 'STUDY_CENTRAL' in kvrage 60 800
com =====ATC 69kV above=====
monitor branches in area 295 in kvrage 60 800
monitor ties from area 295 in kvrage 60 800
monitor branches in area 694 in kvrage 60 800
monitor ties from area 694 in kvrage 60 800
monitor branches in area 696 in kvrage 60 800
monitor ties from area 696 in kvrage 60 800
monitor branches in area 697 in kvrage 60 800
monitor ties from area 697 in kvrage 60 800
monitor branches in area 698 in kvrage 60 800
monitor ties from area 698 in kvrage 60 800
/=====
monitor branches in area 600 in kvrage 60 800
monitor ties from area 600 in kvrage 60 800
monitor branches in area 608 in kvrage 60 800
monitor ties from area 608 in kvrage 60 800
monitor branches in area 613 in kvrage 60 800
monitor ties from area 613 in kvrage 60 800
monitor branches in area 615 in kvrage 60 800
monitor ties from area 615 in kvrage 60 800
monitor branches in area 620 in kvrage 40 800
monitor ties from area 620 in kvrage 40 800
monitor branches in area 627 in kvrage 60 800
monitor ties from area 627 in kvrage 60 800
monitor branches in area 633 in kvrage 60 800
monitor ties from area 633 in kvrage 60 800

```



```
monitor branches in area 635 in kvrage 60 800
monitor ties    from area 635 in kvrage 60 800
monitor branches in area 661 in kvrage 57 800
monitor ties    from area 661 in kvrage 57 800
monitor branches in area 667 in kvrage 60 800
monitor ties    from area 667 in kvrage 60 800
monitor branches in area 680 in kvrage 60 800
monitor ties    from area 680 in kvrage 60 800
```

```
com subsystem seams
```

```
monitor branches in subsystem 'STUDY_SEAMS' in kvrage 60 800
monitor ties    from subsystem 'STUDY_SEAMS' in kvrage 60 800
```

### A.3 Contingency Files

The following three master contingency files were supplied by MISO and applied to the 2016 SPK and SH conditions without any modification.

- 2015-DPP\_Aug-Cycle\_Master-B\_Central\_rev0.con

```
SINGLE BRANCH IN SUBSYSTEM 'STUDY_CENTRAL'
SINGLE UNIT OUTAGE IN SUBSYSTEM 'STUDY_CENTRAL'
SINGLE BRANCH IN SUBSYSTEM 'STUDY_SEAMS'
SINGLE TIE FROM SUBSYSTEM 'CENTRAL_SEAMS'
SINGLE UNIT OUTAGE IN SUBSYSTEM 'STUDY_SEAMS'
include '.\2015\2015-CatB\BREC_2014S_Cat-B_06122012_Explicit.con'
include '.\2015\2015-CatB\DEI_2014S_Cat-B_06122012_Explicit.con'
INCLUDE '.\2015\2015-CatB\HE_2014S_Cat-B_06122012_Explicit.con'
INCLUDE '.\2015\2015-CatB\IPL_2014_Cat-B_06122012_Explicit.con'
INCLUDE '.\2015\2015-CatB\SIGE_2014_Cat-B_06122012.con'
INCLUDE '.\2015\2015-CatB\NIPS_2015_CatB.con'
INCLUDE '.\2015\2015-CatB\B_explicit_AMRN_2015.con'
INCLUDE '.\2015\2015-CatB\B_explicit_AMRN_2017S_fixed.con'
INCLUDE '.\2015\2015-CatB\B_Explicit_SIPC_2017_MISO.con'
INCLUDE '.\2015\2015-CatB\CWLP_MTEP12_CatB.con'
INCLUDE '.\PJM\21S_RFC-PJM_Study_Cat-B1-B2-B3_R1.con'
INCLUDE '.\PJM\ComEd_RTEP_Cat_B.con'
```

- 2015-DPP\_Aug-Cycle\_Master-B\_West\_rev0.con

```
SINGLE BRANCH IN SUBSYSTEM 'STUDY_WEST'
SINGLE TIE FROM SUBSYSTEM 'STUDY_WEST'
SINGLE UNIT OUTAGE IN SUBSYSTEM 'STUDY_WEST'
INCLUDE '.\2015\2015west\2015_ATC_DPP_August_2012_B1_fixed.con'
INCLUDE '.\2015\2015west\2015_ATC_DPP_August_2012_B2_B3_fixed.con'
include '.\2015\2015west\GRE_CONS_B.con'
include '.\2015\2015west\MDU-CON-CAT-B_fixed.con'
```



```
include '..\2015\2015west\MP_CONS_B.con'
include '..\2015\2015west\MRES_MTEP12_Cat-B_edits.con'
include '..\2015\2015west\MTEP12_2017_DPC_Cat_B.con'
include '..\2015\2015west\MTEP12_2017_ITCM_Cat_B_fixed.con'
include '..\2015\2015west\MTEP12_2017_MEC_Cat_B.con'
include '..\2015\2015west\MTEP12_2017_MPW_Cat_B.con'
include '..\2015\2015west\MTEP12_2017_Xcel_Cat_B_fixed.con'
include '..\2015\2015west\OTP_CONS_B_Updated.con'
include '..\2015\2015west\Selected_MDU_CONS_B.con'
include '..\2015\2015west\SMPA_CONS_B.con'
```

- 2015-DPP\_Aug-Cycle\_Master-C-Single\_rev0.con

```
INCLUDE '..\2015\2015west\ATC_MTEP12_2017_C1_C2_fixed.con'
INCLUDE '..\2015\2015west\ATC_MTEP12_2017_C5_fixed.con'
include '..\2015\2015west\ATC_MTEP12_2017_C9_fixed.con'
include '..\2015\2015west\ATC_MTEP12_auto_C3_for_cat_C1_C2_fixed.con'
include '..\2015\2015west\GRE_CONS_C_fixed.con'
include '..\2015\2015west\IS_2017_CAT_C_fixed.con'
include '..\2015\2015west\MDU_CONS_C1.con'
include '..\2015\2015west\MDU-CON-CAT-C_fixed.con'
include '..\2015\2015west\MP_CONS_C_fixed.con'
include '..\2015\2015west\MRES_CONS_C_Updated_fixed.con'
include '..\2015\2015west\MTEP12_2017_DPC_Cat_C.con'
include '..\2015\2015west\MTEP12_2017_ITCM_Cat_C_fixed.con'
include '..\2015\2015west\MTEP12_2017_MEC_Cat_C1_C2_C5_fixed.con'
include '..\2015\2015west\MTEP12_2017_MPW_Cat_C.con'
include '..\2015\2015west\MTEP12_2017_Xcel_Cat_C_fixed.con'
include '..\2015\2015west\OTP_CONS_C_fixed.con'
include '..\2015\2015west\Selected_WAPA_CONS_C_fixed.con'
include '..\2015\2015west\SMPA_CONS_C_fixed.con'
include '..\2015\2015-CatC\C1_Explicit_AMRN_2017.con'
include '..\2015\2015-CatC\C1_Explicit_CWLD_2017_MISO.con'
include '..\2015\2015-CatC\C1_Explicit_SIPC_2017_MISO.con'
include '..\2015\2015-CatC\C2_Explicit_AMRN_2017_fixed.con'
include '..\2015\2015-CatC\C2_Explicit_CWLD_2017_MISO.con'
include '..\2015\2015-CatC\C2_Explicit_SIPC_2017_MISO.con'
include '..\2015\2015-CatC\C5_Explicit_AMRN_2017_fixed.con'
include '..\2015\2015-CatC\C5_Explicit_CWLD_2017_MISO_fixed.con'
include '..\2015\2015-CatC\CWLP_MTEP12_CatC1.con'
include '..\2015\2015-CatC\CWLP_MTEP12_CatC2.con'
include '..\2015\2015-CatC\CWLP_MTEP12_CatC5.con'
include '..\2015\2015-CatC\BREC_2014S_Cat-C12_06122012_Explicit.con'
include '..\2015\2015-CatC\BREC_2014S_Cat-
C125_06122012_BusDoubleAuto.con'
include '..\2015\2015-CatC\DEI_2014S_CatC1_C2_06122012_Explicit.con'
include '..\2015\2015-CatC\DEI_2014S_CatC5_06122012_Explicit.con'
include '..\2015\2015-CatC\HE_2014S_Cat-C_06122012_BusDouble-auto.con'
include '..\2015\2015-CatC\IPL_2014S_Cat-C125_06122012_Explicit.con'
include '..\2015\2015-CatC\NIPS_2015_CatC.con'
```



```
include'.\2015\2015-CatC\SIGE_2014S_Cat-
C125_06122012_BusDoubleAuto.con'
INCLUDE '.\PJM\21S_RFC-PJM_Study_Cat-C1-C2-C3-C5_R1.con'
INCLUDE '.\PJM\ComEd_RTEP_Cat_C.con'
```

The following three master contingency files were supplied by MISO and applied to the 2023 SPK and SH conditions without any modification.

- 2022-DPP\_Aug-Cycle\_Master-B\_Central\_rev0.con

```
SINGLE BRANCH IN SUBSYSTEM 'STUDY_CENTRAL'
SINGLE UNIT OUTAGE IN SUBSYSTEM 'STUDY_CENTRAL'
SINGLE BRANCH IN SUBSYSTEM 'STUDY_SEAMS'
SINGLE TIE FROM SUBSYSTEM 'CENTRAL_SEAMS'
SINGLE UNIT OUTAGE IN SUBSYSTEM 'STUDY_SEAMS'
INCLUDE '.\2022\2022-CatB\B_explicit_AMRN_2022.con'
INCLUDE '.\2022\2022-CatB\B_Explicit_SIPC_2022_MISO.con'
INCLUDE '.\2022\2022-CatB\CWLP_MTEP12_CatB.con'
INCLUDE '.\2022\2022-CatB\BREC_2022S_Cat-B_06122012_Explicit.con'
INCLUDE '.\2022\2022-CatB\DEI_2022S_CatB_06122012_Explicit.con'
INCLUDE '.\2022\2022-CatB\HE_2022S_Cat-B_06122012_Explicit.con'
INCLUDE '.\2022\2022-CatB\IPL_2022_Cat-B_06122012_Explicit.con'
INCLUDE '.\2022\2022-CatB\NIPS_2022_CatB.con'
INCLUDE '.\2022\2022-CatB\SIGE_2022S_Cat-B_06122012.con'
INCLUDE '.\PJM\21S_RFC-PJM_Study_Cat-B1-B2-B3_R1.con'
INCLUDE '.\PJM\ComEd_RTEP_Cat_B.con'
```

- 2022-DPP\_Aug-Cycle\_Master-B\_West\_rev0.con

```
SINGLE BRANCH IN SUBSYSTEM 'STUDY_WEST'
SINGLE TIE FROM SUBSYSTEM 'STUDY_WEST'
SINGLE UNIT OUTAGE IN SUBSYSTEM 'STUDY_WEST'
INCLUDE '.\2022\2022west\2022_ATC_DPP_August_2012_B1_fixed.con'
INCLUDE '.\2022\2022west\2022_ATC_DPP_August_2012_B2_B3_fixed.con'
include '.\2022\2022west\GRE_CONS_B.con'
include '.\2022\2022west\MDU-CON-CAT-B_fixed.con'
include '.\2022\2022west\MP_CONS_B.con'
include '.\2022\2022west\MRES_MTEP12_Cat-B_edits.con'
include '.\2022\2022west\MTEP12_2022_DPC_Cat_B.con'
include '.\2022\2022west\MTEP12_2022_ITCM_Cat_B_fixed.CON'
include '.\2022\2022west\MTEP12_2022_MEC_Cat_B.con'
include '.\2022\2022west\MTEP12_2022_MPW_Cat_B.con'
include '.\2022\2022west\MTEP12_2022_Xcel_Cat_B_fixed.con'
include '.\2022\2022west\OTP_CONS_B_Updated.con'
include '.\2022\2022west\Selected_MDU_CONS_B.con'
include '.\2022\2022west\SMPA_CONS_B.con'
```

- 2022-DPP\_Aug-Cycle\_Master-C-Single\_rev0.con

```
INCLUDE '.\2022\2022west\ATC_MTEP12_2022_C1_C2_fixed.con'
INCLUDE '.\2022\2022west\ATC_MTEP12_2022_C5_fixed.con'
```



```

include '..\2022\2022west\ATC_MTEP12_2022_C9_fixed.con'
include '..\2022\2022west\ATC_MTEP12_auto_C3_for_cat_C1_C2_fixed.con'
include '..\2022\2022west\GRE_CONS_C_fixed.con'
include '..\2022\2022west\IS_2022_CAT_C_fixed.con'
include '..\2022\2022west\MDU_CONS_C1.con'
include '..\2022\2022west\MDU-CON-CAT-C_fixed.con'
include '..\2022\2022west\MP_CONS_C_fixed.con'
include '..\2022\2022west\MRES_CONS_C_Updated.con'
include '..\2022\2022west\MTEP12_2022_DPC_Cat_C.con'
include '..\2022\2022west\MTEP12_2022_ITCM_Cat_C_fixed.CON'
include '..\2022\2022west\MTEP12_2022_MEC_Cat_C1_C2_C5_fixed.con'
include '..\2022\2022west\MTEP12_2022_MPW_Cat_C.con'
include '..\2022\2022west\MTEP12_2022_Xcel_Cat_C_fixed.con'
include '..\2022\2022west\OTP_CONS_C_fixed.con'
include '..\2022\2022west\Selected_WAPA_CONS_C_fixed.con'
include '..\2022\2022west\SMPA_CONS_C_fixed.con'
include '..\2022\2022-CatC\C1_Explicit_AMRN_2022.con'
include '..\2022\2022-CatC\C1_Explicit_CWLD_2022_MISO.con'
include '..\2022\2022-CatC\C1_Explicit_SIPC_2022_MISO.con'
include '..\2022\2022-CatC\C2_Explicit_AMRN_2022_fixed.con'
include '..\2022\2022-CatC\C2_Explicit_CWLD_2022_MISO.con'
include '..\2022\2022-CatC\C2_Explicit_SIPC_2022_MISO.con'
include '..\2022\2022-CatC\C5_Explicit_AMRN_2022_fixed.con'
include '..\2022\2022-CatC\C5_Explicit_CWLD_2022_MISO_fixed.con'
include '..\2022\2022-CatC\CWLP_MTEP12_CatC1.con'
include '..\2022\2022-CatC\CWLP_MTEP12_CatC2.con'
include '..\2022\2022-CatC\CWLP_MTEP12_CatC5.con'
include '..\2022\2022-CatC\SIPCAutoCdub.con'
include '..\2022\2022-CatC\BREC_2022S_Cat-C12_06122012_Explicit.con'
include '..\2022\2022-CatC\BREC_2022S_Cat-
C125_06122012_BusDoubleAuto.con'
include '..\2022\2022-CatC\DEI_2022S_CatC5_06122012_Explicit.con'
include '..\2022\2022-CatC\DEI_2022S_CatC1_C2_06122012_Explicit.con'
include '..\2022\2022-CatC\HE_2022S_Cat-C_06122012_BusDoubleAuto.con'
include '..\2022\2022-CatC\IPL_2022S_Cat-C125_06122012_Explicit.con'
include '..\2022\2022-CatC\NIPS_2022_CatC.con'
include '..\2022\2022-CatC\SIGE_2022S_Cat-
C125_06122012_BusDoubleAuto.con'
INCLUDE '..\PJM\21S_RFC-PJM_Study_Cat-C1-C2-C3-C5_R1.con'
INCLUDE '..\PJM\ComEd_RTEP_Cat_C.con'

```